



# CERTIFICATE OF ANALYSIS

## Barnstable County Health Laboratory (M-MA009)

Page: 1 of 1

**Report Prepared For:**

Report Dated: 05/05/2016

Sandy Cashen

Dennis-Yarmouth Regional School District Maint.

296 Station Avenue

S Yarmouth, MA 02664

Order No.: G1692738

**Laboratory ID #: 1692738-01**

Description: Water - Drinking Water

Sample #:

Sample Location: Rm 307 Retest

Collected: 04/30/2016

Collected by: REM

62-12

Received: 05/02/2016

**Test Parameters**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	NOTE
Copper	0.085	mg/L	0.0010	1.3	EPA 200.8	VZ	05/04/2016	
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	VZ	05/04/2016	

**Laboratory ID #: 1692738-02**

Description: Water - Drinking Water

Sample #:

Sample Location: Rm 202 New

Collected: 04/30/2016

Collected by: REM

6235

Received: 05/02/2016

**Test Parameters**

ITEM	RESULT	UNITS	RL	MCL	METHOD #	ANALYST	TESTED	NOTE
Copper	0.15	mg/L	0.0010	1.3	EPA 200.8	VZ	05/04/2016	
Lead	ND	mg/L	0.0010	0.015	EPA 200.8	VZ	05/04/2016	

Attached please find the laboratory certified parameter list.

Approved By: *Jongmin Lei*  
(Lab Manager)

5/5/2016

These tests taken after report to make sure all is ok

ND = None Detected

RL = Reporting Limit

MCL = Maximum Contaminant Level

3195 Main Street, PO. Box 427, Barnstable, MA 02630 Ph: 508-375-6605